REQUEST NUMBER: 2026-14361

ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ

Electrotechnical Laboratory (Gebze)

Yapı Malzemeleri Yönetmeliği(305/2011/AB)
Construction Products Regulation(305/2011/EU)

ONAYLANMIŞ KURULUŞ : 1783

NOTIFIED BODY : 1783

TS EN 13501-6

YANGINA TEPKİ SINIFLANDIRMA RAPORU

REACTİON TO FIRE CLASSIFICATION REPORT

Talep Eden : BESAV KABLO A.Ş.
Applicant
Adresi : KOZLUK MAH. D-100 YANYOL CAD. NO:219 A
ERENLER / SAKARYA
Address

Name and address of Production Place
Markası,Ticari Modeli,Tipi : BESAV KABLO YVV 0,6/1 kV
Trade Mark, Commercial Model,Type

YANGINA TEPKİ SINIFI

REACTİON TO FIRE CLASSIFICATION

E

Rapor Değerlendirme Tarihi : 13.02.2026
Report Assessment Date

SAFİYE DEMİR
DIRECTOR OF ELECTROTECHNICAL LABORATORY (GEBZE) DEP.

Bu rapor 3 sayfadır ve kısmen çoğaltılamaz.
This report is composed of 3 page and cannot be copied partially.
Adres: TSE Kalite Kampüsü Cumhuriyet Mah. 2258 Sok. No:10 H- Blok Gebze KOCAELI TÜRKİYE
Tel: +90 2627231526 e-posta: elektroteknikgebze@tse.org.tr web: www.tse.org.tr

1. INTRODUCTION

REQUEST NUMBER:2026-14361

This classification report defines the classification of cable below in accordance with the procedures given in TS EN 13501-6

2. DETAILS OF CLASSIFIED PRODUCT

2.1. General

Trade name, Type of cable	BESAV KABLO YVV 0,6/1 kV	
Tested cable and size and overall diameter	1- YVV 0,6/1 kV 2x6 mm² 2- YVV 0,6/1 kV 5G1,5 mm²	14,12 mm 13,50 mm

3. TEST REPORT AND RESULTS

3.1 Test Reports

Name of Laboratory	Test reports no and Date	Test methods
TSE Ankara Electrotechnical Laboratory	238747 / 08-24	(TS EN 60332-1-2/A1:2016 / A12: 2021)
TSE Ankara Electrotechnical Laboratory	238692 / 08-24	(TS EN 60332-1-2/A1:2016 / A12: 2021)

3.2 Test Results

Test method and type of cable	Parameter	No. of test	Test results	
			Continuous parameter	Compliance with parameters
YVV 0,6/1 kV 2x6 mm² TS EN 60332-1-2/A12:2021	H (Vertical flame spread)	1	120 mm	≤ 425mm / Eca
YVV 0,6/1 kV 5G1,5 mm² TS EN 60332-1-2/A12:2021	H (Vertical flame spread)	1	85 mm	≤ 425mm / Eca

4. CLASSIFICATION

Fire Behaviour	Smoke Production	Flaming Droplets	Acidity
E*ca*	-	-	-

Reaction to Fire Classification: E*ca*

5. Field of Application

REQUEST NUMBER:2026-14361

This classification is valid for the power cables listed below as determined in the extended application process according to CLC-FprTS 50576-2016.

Trade name	Cable Family	Outer diameter of cable	Reaction to Fire Classification
BESAV KABLO	YVV 0,6/1 kV	From13,50 mm – to 17,65 mm	E*ca*

Prepared by

MÜNİR ÖZKAYA

TEST STAFF

Approved by

SAFİYE DEMİR

DIRECTOR OF ELECTROTECHNICAL LABORATORY (GEBZE) DEP.